

October 2022 Solicitation Questions and Responses

Solicitation	Project	Question	Response
NC-02	6950-04-04	Are easements or real estate acquisitions anticipated as a result of culvert replacements or beam guard work?	Real estate is anticipated for culverts; not beam guard.
NC-03	6530-01-00	Will the consultant be responsible for the development of an intersection control evaluation study?	No. No anticipated changes to traffic control at the intersection.
NC-03	6530-01-00	Are the CTH YY intersection improvements expected to be accommodated within the existing right of way?	TBD
NE-01	4075-42-00	Can you please clarify the nature of "secondary" structure work on the two box culverts?	Anticipating wingwall replacements on C-05-0086 and C-05-0083.
NE-02	1100-56-00	What work is intended for the "secondary structure design"?	TBD
SE-03	1090-03-07	Is curb and gutter inspection and repair part of the project scope?	No
SW-02	7660-00-02	What is the anticipated structural work on SW02?	<p>B-29-105: Replace both concrete approach slabs, Concrete Surface Repair along north/west drip edge/fascia of bridge deck, Surface repair on NW wing and a few small areas on the abutments.</p> <p>B-29-066: Repair damage to the leading deck edge of the deck damaged by snow plow, Concrete Surface Repair the underside of the slab at the fascia and soffit area.</p>