

- * "A" = PRESTRESS CAMBER
- * "B" = DEAD LOAD DEFLECTION * ROUND OFF TO NEAREST 1/8"
- * "C" = RESIDUAL CAMBER

DESIGNER NOTES

PRESENT PRACTICE IS TO USE A MINIMUM "HAUNCH HEIGHT" (AT EDGE OF GIRDER FLANGE) OF 2" FOR DESIGN CALCULATIONS.

THE MINIMUM HAUNCH (AT EDGE OF GIRDER FLANGE) ALLOWED IN CONSTRUCTION IS 1/4".


USE THE CALCULATED THEORETICAL AVERAGE "HAUNCH HEIGHT" AT CENTERLINE OF FLANGE FOR COMPUTING THE HAUNCH CONCRETE QUANTITY.

USE TOP OF DECK ELEVATIONS AND CALCULATED "HAUNCH HEIGHT" AT CENTERLINE OF GIRDER FOR COMPUTING BEAM SEAT ELEVATIONS AT SUBSTRUCTURES.

"INTERMEDIATE CONCRETE DIAPHRAGMS" SHALL BE USED ONLY WHEN THE USE OF STEEL DIAPHRAGMS IS NOT FEASIBLE BECAUSE OF UTILITIES OR FOR OTHER SPECIAL SITUATIONS. ONLY ONE TYPE OF INTERMEDIATE DIAPHRAGM SHALL BE SHOWN ON THE PLANS. THE USE OF BOTH INTERMEDIATE CONCRETE & STEEL DIAPHRAGMS ON THE SAME BRIDGE IS NOT ALLOWED.

FOR SKEWS $\leq 10^\circ$, PLACE INTERMEDIATE DIAPHRAGMS IN A STRAIGHT LINE. REFER TO STANDARD 19.36. PROVIDE OFFSET FOR SKEWS $> 10^\circ$.

PIER PILASTERS ARE TYPICALLY NOT USED, BUT MAY BE USED AS PART OF THE BRIDGE AESTHETIC PACKAGE ON 28", 36", 45", 54" AND 70" PRESTRESSED GIRDERS. PILASTERS ARE NOT USED ON 36W", 45W", 54W", 72W" OR 82W".




IF 1/4" MINIMUM HAUNCH HEIGHT AT EDGE OF GIRDER CANNOT BE MAINTAINED, THE GRADE LINE MAY BE REVISED BY THE ENGINEER AT THE OPTION OF THE CONTRACTOR. THE PLAN DECK THICKNESS SHALL BE HELD, NOTIFY THE STRUCTURES SECTION IF THE GRADE LINE IS RAISED FROM THE PLAN PROFILE BY MORE THAN 1/2" OR, ** IF 3" MINIMUM DECK EMBEDMENT OF TIE BAR CANNOT BE OBTAINED.



TO DETERMINE "T", ELEV. OF TOP OF GRS. AT ϕ OF SUBSTRUCTURE UNITS & AT 1/10 POINTS OF EACH SPAN SHALL BE TAKEN. THEN FOLLOW THIS PROCESS:

TOP OF DECK ELEV. AT FINAL GRADE
 - TOP OF GIRDER ELEVATION
 + DEAD LOAD DEFLECTION
 - DECK THICKNESS
 = HAUNCH HEIGHT "T"

NOTE: AN AVERAGE HAUNCH ("T") WAS USED IN THE QUANTITY "CONCRETE MASONRY BRIDGES".



GIRDER DEPTH	DIAPHRAGM WEIGHT
28"	207#/FT.
36"	270#/FT.
36W"	259#/FT.
45"	338#/FT.
45W"	353#/FT.
54"	405#/FT.
54W"	446#/FT.
70"	634#/FT.
72W"	634#/FT.
82W"	738#/FT.



PRESTRESSED GIRDER DETAILS

BUREAU OF STRUCTURES

WISCONSIN DEPARTMENT OF TRANSPORTATION

DATE: 1-19

APPROVED: *Laura Shadewald*