



Wisconsin Department of Transportation

Division of Transportation Systems Development

Bureau of Project Development
4802 Sheboygan Avenue, Rm 601
P O Box 7916
Madison, WI 53707-7916

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

December 7, 2017

NOTICE TO ALL CONTRACTORS:

Proposal #01: 4650-08-71, WISC 2017 623
City of Kaukauna, Delanglade Street
Lawe Street – IH 41
STH 55
Outagamie County

Letting of December 12, 2017

This is Addendum No. 03, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
30	Catch Basins, Manholes, and Box Manholes
42	Concrete Masonry Special, Item SPV.0035.02
43	Internal Chimney Seal 1-Piece, Item SPV.0060.02; Internal Chimney Seal 2-Piece, Item SPV.0060.03
59	Steel Casing Pipe 42-Inch, Item SPV.0090.10

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 03

4650-08-71

December 7, 2017

Special Provisions

30. Catch Basins, Manholes, and Box Manholes.

Add the following paragraph:

A precast manhole may be furnished in lieu of the cast in place box manholes M-44-1, M-44-2, M-44-3 and M-44-4. The precast structure shall conform to layout dimensions on the plans and AASHTO LRFD Bridge Design Specifications. Have a professional engineer, registered in the state of Wisconsin and knowledgeable of the specific site conditions and requirements, verify the adequacy of the design. Submit one copy of each precast box design, signed and sealed by the same professional engineer verifying the design, to the engineer for incorporation into the permanent project record. Payment for the precast manhole shall be based on the prices bid for the items listed in the "Total Estimated Quantities" in each structure plan. All precast manholes shall be placed on a bedding of "Structure Backfill Type B" of 6" minimum depth.

42. Concrete Masonry Special, Item SPV.0035.02.

Replace entire article language with the following:

A Description.

This special provision describes the concrete masonry construction of cast in place manhole/inlet structures in accordance with the requirements pertaining to culverts in Section 504, manhole and inlets in Section 611, and QMP in Section 715 of the standard specifications and as hereinafter provided.

B Materials.

Provide steel reinforcement and concrete specified in the plans and details and Section 504 of the standard specifications.

Provide QMP as specified in Section 715 of the standard specifications.

Provide trench backfill as specified for manholes and inlets in Section 611 of the standard specifications.

Furnish grade A air-entrained concrete conforming to Section 501 for the structure flowline.

C Construction.

Construct manhole/inlet structures in accordance with Section 504 of the standard specifications.

Excavate and backfill the manhole/inlet structures in accordance with Section 611 of the standard specifications and as follows: if utilities and other restraints make sloping or benching of the excavation impracticable, employ a shoring system.

Fill bottom of structure with grade A concrete to flowline. Slope sides a minimum of 1 inch/foot to flowline. Concrete flowline is incidental to Concrete Masonry Special.

D Measurement.

The department will measure Concrete Masonry Special by the cubic yard acceptably completed. The department will not measure work or materials for excavation, backfill, forms, falsework, or cofferdams unless specified otherwise. The department will not measure pumping, bracing, concrete for structure flowline or other incidentals necessary to complete the work.

E Payment.

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0035.02	Concrete Masonry Special	CY

Payment is full compensation for furnishing all materials, forms, excavation, providing and removing sheeting and shoring, backfilling, falsework, placing, finishing, curing, protecting, and heating.

43. Internal Chimney Seal 1-Piece, Item SPV.0060.02; Internal Chimney Seal 2-Piece, Item SPV.0060.03

Add the following paragraph under section titled D Measurement:

If an oversized seal is used in lieu of a base seal and extension (2-Piece), payment will be made under the 2-Piece pay item.

59. Steel Casing Pipe 42-Inch, Item SPV.0090.10.

Replace entire paragraph under section titled B.1 Smooth Steel Casing Pipe with the following:

Furnish pipe made of steel that has a plain end, a minimum thickness of 0.625", minimum yield strength of 35,000 psi, and conforms to ASTM A106 Grade B, ASTM A252 Grade 2 or ASTM A252 Grade 3. Furnish pipe that has welded joints, is in at least 18 ft long sections (except for the last section, if a shorter length is needed to obtain the total length.)

END OF ADDENDUM

